GANPAT UNIVERSITY

B. Tech. Semester: IV (Mechatronics Engineering)

Regular (CBCS) Examination/ April - June 2015

Energy Conversion Systems (2MC406)

| Time: 3 H | ours | Total Marks | s: 70 |
|-------------|------------|--|-------|
| Instruction | 2. 3. | Attempt All The Questions. Use of Steam table and Psychrometric Chart is Allow. Use of Non-programmable scientific calculator is permitted. Don't write anything on question paper. | |
| | | SECTION - I | |
| Que 1 | (A) | Explain the Vapour Compression Refrigeration system with schematic diagram. Draw the P-H and T-S diagram for the same. | 6 |
| | (B) | Explain Vapour Absorption Refrigeration System. Give its advantages over Vapour compression refrigeration system. | 6 |
| | | OR Define at the state of the s | 6 |
| Que1 | (A) | Enlist Various Components of Vapour Compression Refrigeration system and explain refrigerator evaporators and its types. | |
| | (B) | What are the desirable properties for a good refrigerant? | 6 |
| Que2 | (A) | Explains the following terms (i) Dry Air (ii) Absolute Humidity (iii) Relative Humidity (iv) Degree of saturation (v) Wet Bulb Temperature | 5 |
| | (B) | What is by-pass factor derive the expression for the same? OR | 6 |
| Que2 | (A) | Explain Nuclear Reactor with diagram. | 5 |
| | (B) | Explain Rankine Cycle with P-V chart and derive an expression for efficiency of Rankine Cycle. | 6 |
| Que3 | (A) (B) | Draw layout of modern thermal power plant and enlist its various circuits. What are the factors affecting site selections of thermal power plant? | 6 |
| | | SECTION – II | |
| Que4 | (A) | A R-12 Refrigeration Machine has saturated suction temperature of 5° C and saturated discharge temperature of 40° C. Determine C.O.P. of the system. Temp. (°C) Pressure (bar) Volume Vapour (m³/kg) Enthalpy (kJ/kg) Entropy(kJ/kg-K) Specific heat (kJ/kg K) Vapour (m³/kg) Liquid Vapour Liquid Vapour Liquid Vapour Liquid Vapour 6 3.6375 0.04799 204.68 354.885 1.01685 1.5568 0.938 0.646 40 9.5909 0.01837 239.03 368.81 1.1315 1.5459 1.030 0.762 | 6 |
| | (B) | What is Refrigeration? Explain and derive 1 Ton refrigeration. | 6 |
| | | OR | |
| Que 4 | (A) | A R-12 Vapour compression Refrigeration System has a Condensing temperature of 50°C and Evaporating temperature of 0°C. The refrigeration Capacity is 7 tons. The liquid leaving the condenser is saturated liquid and compression is isentropic. Determine (i) Refrigerant Flow rate (ii) Power required to run the Compressor (iii) Heat rejected in the plant (iv) COP of the System. | 6 |
| | (B) | Explain Electrolux refrigerator with neat sketch. | 6 |
| | | | |

The barometer for atmospheric air reads 750 mm Hg. The dry bulb temperature is 33°C; wet bulb temperature is 23°C. determine (ii) Humidity Ratio (i) Relative humidity (iv) Density of Air (iii) Dew Point Temperature A 4-S 4 Cylinder diesel engine running at 2000 rpm develops 60 W with break 6 thermal efficiency of 30% and CV of the fuel is 42 MJ/kg. Engine bore is 120 mm and stroke is 100 mm if density of air is 1.15 kg/m³ with air fuel ratio of 15:1 with mechanical efficiency of 80%. Determine (ii) Air Consumption (m³/s) Fuel Consumption (kg/s) (i) (iv) Volumetric Efficiency Indicating Thermal Efficiency (iii) (vi) Piston Speed Break Mean Effective Pressure (v) OR The humidity ratio of atmospheric air at 27.5°C is 0.016 kg/kg of air. Determine 5 Que.-5 (A) (i) partial pressure of vapour (ii) relative humidity (iii) dew point temperature Assume standard barometric pressure of 760 mm of Hg. An Engine working on Otto Cycle has a Clearance of 1% of stroke volume and 6 Initial pressure of 0.95 bar and temperature 30°C. if the pressure at the end of Constant volume heating is 28 bar. Find An air standard Efficiency (i) The maximum temperature in the cycle (ii) Ideal mean effective Pressure (iii) In a Rankine Cycle, the steam at inlet to turbine is saturated at a pressure of 30 bar 6 Oue.-6 and exhaust pressure is 0.25 bar. Determine pump work, Turbine Power, Rankine Efficiency, Condenser Heat Flow, dryness Fraction at the end of Expansion. Assume Flow Rate of 10 kg/s. A steam Power Plant operates at a boiler pressure of 50 kgf/cm² and condenser 6

600316 9023480 866033

> Emark Emark Podation Podation

(B) A steam Power Plant operates at a boiler pressure of 50 kgf/cm² and condenser pressure of 0.05 kgf/cm², steam coming out of the boiler is dry and saturated. Calculate the thermal efficiency if it operates on Rankine Cycle.

ALL THE BEST